



# Certificate of Compliance

**Certificate:** 2639627

**Master Contract:** 205096

**Project:** 2639627

**Date Issued:** January 27, 2014

**Issued to:** Industrial Enclosure Corporation

619 North Loucks Street  
Post Office Box 2817  
Aurora, IL 60507  
USA  
Attention: Mark Siegler

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



Wendy Zhu

**Issued by:** Wendy Zhu, Ph.D., P. Eng

## **PRODUCTS**

**CLASS 3211 07** - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

**CLASS 3211 87** - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus -  
Certified to US Standards

Enclosures for industrial control equipment. IEC series, metal, with environmental ratings as below:

IEC-SDXXXXXX, IEC-TDXXXXXX, IEC-XXXXXXSLT TYPE 1, 3R, 4, 12

IEC-SDXXXXXXXXSS, IEC-DSCXXXXXXXXSS, IEC-XXHXXXXSSLP, IEC-XXHXXXXSSFS, IEC-TDXXXXXXXXSS, IEC-XXHXXXXSSFS TYPE 4X

IEC-XXHXXXALP, IEC-XXHXXXBLP, IEC-XXHXXCLP, IEC-XXHXXDLP, IEC-XXHXXFLP, IEC-XXHXXCLP, IEC-XXHXXDLP, IEC-XXHXXFLP, IEC-XXHXXHLP, IEC-XXHXXJLP, IEC-XXHXXXXFS, IEC-XXHSXXXXLP, TYPE 4

IEC-XXXXXXLP, IEC-XXXXXXWFLP, IEC-XXXXXXLP, TYPE 1, 3R, 12



**Certificate:** 2639627

**Master Contract:** 205096

**Project:** 2639627

**Date Issued:** January 27, 2014

---

IEC-XXXXXXXXLPFTC, IEC-XXCPXXXXXXXXLPFTC, IEC-XXSAXXXXXLPPL, IEC-XXXMXXXXFTC, IEC-XXXMXXXXFTC, IEC-XXXM3EWXXFTC, IEC-XXXM4EWXXFTC, IEC-XXXM5EWXXFTC, IEC-XXXM6EWXXFTC, IEC-XXXXXXFS, IEC-XXXXXXFSDA, IEC-XXXXXXFSD, IEC-XXXXXXFSDAD, TYPE 12

IEC-XXXXXXCH, IEC-XXXXXXSC, IEC-XXXXXXCC, IEC-MODXXXXXX, TYPE 1, 3R, 12, 4, 4X

IEC-241312DC, TYPE 3R

### **Model Numbering system nomenclature**

X	0-9
SD	IEC line SINGLE DOOR
TD	IEC line Two Door
SS	STAINLESS STEEL
LP	LESS PANEL
H	Type 4 OR 4X
ALP	6 INCHES DEPTH LESS PANEL
BLP	8 INCHES DEPTH LESS PANEL
CLP	10 INCHES DEPTH LESS PANEL
DLP	12 INCHES DEPTH LESS PANEL
ELP	14 INCHES DEPTH LESS PANEL
FLP	16 INCHES DEPTH LESS PANEL
GLP	18 INCHES DEPTH LESS PANEL
HLP	20 INCHES DEPTH LESS PANEL
ILP	22 INCHES DEPTH LESS PANEL
JLP	24 INCHES DEPTH LESS PANEL
WFLP	WIDE FRONT LESS PANEL
FS	FREE STANDING
FTC	FLANGE TROUGH COLLAR



**Certificate:** 2639627

**Master Contract:** 205096

**Project:** 2639627

**Date Issued:** January 27, 2014

---

LPPL	LESS PANEL PAD LOCK HANDLE
FSD	FREE STANDING DOUBLE DOOR
FSDA	FREE STANDING DUAL ACCESS
FSDAD	FREE STANDING DUAL ACCESS DOUBLE
DC	DIGITAL CONTROL
x	TYPE 12
M	MASTER
CH	CONTINUOUS HINGE
SC	SCREW COVER
CC	CONSOLE CABINET
MOD	MODULAR
EW	EXTRA WIDE
SA	SAFTEY ACCESS
CP	CENTER POST
SLT	SLOPED TOP

**APPLICABLE REQUIREMENTS**

CAN/CSA –C22.2 No. 14	Industrial Control Equipment
CAN/CSA-C22.2 No.94	Special Purpose Enclosures
CSA C22.2 NO. 94.2*	Enclosures for Electrical Equipment, Environmental Considerations

\* For Type 1 enclosures only.